

6

Output Specification and Wiring Methods

In this chapter we tell the output specification and external wiring methods of XC series PLC. The connection method differs according to different model; the main reason is the terminal's position. For each model's terminal arrangement, please refer to chapter 2-3;

6-1. Output Specifications

6-2. Relay Output Type


6-3. Transistor Output Type

6-1. Output Specification

1


Relay Output

Interior power		Below AC250V、DC30V
Circuit insulation		Mechanism insulation
Action denote		LED indicate lamp
Max load	Resistant load	3A
	Induce load	80VA
	Lamp load	100W
Open circuit's leak current		-
Mini load		DC5V 2mA
Response time	OFF→ON	10ms
	ON→OFF	10ms



2	Normal Transistor Output
---	---------------------------------

Interior power		Below DC5~30V
Circuit insulation		Optical coupling insulation
Action denote		Indicate lamp LED
Max load	Restance load	0.8A
	Induce load	12W/DC24V
	Lamp load	1.5W/DC24V
Open circuit's leak current		-
Mini load		DC5V 2mA
Response time	OFF→ON	Below 0.2ms
	ON→OFF	Below 0.2ms




3 High Speed Pulse Output

Model	RT or T Type
High Speed Pulse Output Terminal	Common models are Y0、Y1; XC5-24/32 model is Y0~Y3
External Power Supply	Below DC5~30V
Action Indication	LED Lamp
Maximum Current	50mA
Max output frequency of pulse	400KHZ


6-2. Relay Output Type

1 Relay Output Circuit



- **Output terminals**
Relay output type includes 2~4 public terminals. So each public-end unit can drive different power-voltage system's (E.g.: AC200V, AC100V, DC24V etc.) load.
- **Circuit's insulation**

2 **Output Connection Example**




3


Constitution of output circuit

- For DC induce load, please parallel connect with commutate diode. If not connect with the commutate diode, the contact's life will be decreased greatly. Please choose the commutate diode which allow inverse voltage endurance up to 5~10 times of the load's voltage, ordinal current exceeds load current.
- Parallel connect AC induce load with surge absorber can reduce noise.

4

DC Load

5

AC Load


6-3. Transistor Output Type

Transistor output models support high speed pulse output and normal transistor these two types;


1

Normal Transistor Output

- Output Terminals
There are 1~4 COM outputs on transistor output type CPU units
- External Power Supply
Please use DC5~30V this stable power supply to drive the load drive.
- Circuit Isolation
Inside PLC, we use optical couples to isolate the internal circuit with the output transistors; besides, public blocks isolate to each other.
- Action Indication
When driving optical couples, LED will be ON, the output transistors will be ON;
- Response Time
From optical couple being ON (or OFF) to transistor being ON (or OFF), PLC needs time below 0.2ms.
- Output current
Each output's current is 0.5A. But limited by the temperature rising, every 4 points' total current should be below 0.8A.
- Open circuit current
Below 0.1mA



E.g.: Below is the connection diagram of RT/T type PLC with stepping driver:



(Make sure the driver's optical couple's input terminal has 8~15mA reliable current)

